



- | | |
|---|----------------------------|
| 1. VACUUM INTERRUPTOR | 8. WIRE MESH |
| 2. OPERATING MECHANISM (S.S.E. OR MAG.) | 9. LV COMPARTMENT |
| 3. INTERLOCKED MECHANICALS | 10. SUPPORT LEGS |
| 4. ROOF BUSHINGS 1200A TO 3000A | 11. NAME PLATE |
| 5. CURRENT TRANSFORMERS (TO C800) | 12. VIEWING WINDOW |
| 6. INSULATED COPPER CONDUCTOR TO 3000A | 13. LOCKABLE DOOR HANDLE |
| 7. FLEX CONNECTORS | 14. LOCKABLE MANUAL HANDLE |

DIMENSIONS ARE IN INCHES AND mm
GENERAL TOLERANCE: ±3mm
IF NOT SPECIFIED

National Breaker Services, LLC 140 TURNPIKE DRIVE MIDDLEBURY, CT 06762	PART TOLERANCES FRACTIONS ± 1/32 .XX ±.032 .XXX ±.010 ANGLE ±.5° CONCENTRICITY ±.015 TIR	ASSEMBLY TOLERANCES FRACTIONS ± 1/4 .XX ±.125 UNLESS OTHERWISE SPECIFIED ALL DIMENSIONS ARE IN INCHES REMOVE ALL BURRS & SHARP EDGES	This drawing is the exclusive property of NBS and is to be returned immediately upon request. The information, designs, etc. shown hereon are confidential and are not to be divulged or submitted to others, nor copied.	DRAWN BY: FF CHECKED BY: BH PROJECT ENG: NBS FILE NO.	DATE: 11/01/2021 DATE: 11/01/2021 DATE:	USED ON: CUSTOMER: PROJECT NO. P.O. NO.	SHEET 1 OF 1 SCALE: NTS SIZE: B REV.	TITLE: G. A. DWG FOR FREE STANDING SWITCHGEAR TO 38.0KV, 3000AMPS 44KA MATL. DWG NO. PART NO. -1 QTY. 1
	NATIONAL BREAKER SERVICES, LLC 140 TURNPIKE DRIVE MIDDLEBURY, CT 06762 TEL: 860-389-1111 FAX: 860-389-1112 WWW.NATIONALBREAKERSERVICES.COM							